



**Addendum Number 2**

**Police Department Rooftop HVAC Unit Removal & Replacement Project**

**Issued February 28, 2025**

**Addendum Description**

Clarification information for requirements of RTUs to connect to the building automation system.

Bid due date and opening is being moved to **Thursday, March 6, 2025, at 10:00 am.**

**Action Required**

- 1. Please sign below acknowledging the Addendum.**
- 2. Return this page with your proposal.**

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

\_\_\_\_\_  
Printed Name

\_\_\_\_\_  
Title

**Clarification:**

*The RTU's will need to come with BACnet communications interface and wok with the existing building automation system.*

**New Bid Due Date:**

***Thursday, March 6, 2025, at 10:00 am***